

### Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow <sup>1</sup> (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.227	69.7%	6.641	88.6%	1.3
Crooked Creek	1.9	1.211	63.7%	1.680	88.4%	0.6
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	0.7
Tallwood	0.05	0.020	40.0%	0.020	40.0%	0.9
Grassy Branch	0.05	0.038	76.0%	0.039	78.0%	0.9

<sup>1</sup>Based on a 12-month rolling average.

### Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	5	0.280
Engineering Plan Review	15	0.380
Sketch Plan Review	11	0.363
<b>Totals</b>	<b>31</b>	<b>1.023</b>

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	5	0.129
Engineering Plan Review	5	0.173
Sketch Plan Review	8	0.152
<b>Totals</b>	<b>18</b>	<b>0.454</b>