

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.245	69.9%	6.733	89.8%	8.7
Crooked Creek	1.9	1.123	59.1%	1.698	89.4%	6.8
Olde Sycamore	0.15	0.041	27.3%	0.041	27.3%	8.0
Tallwood	0.05	0.020	40.0%	0.020	40.0%	7.3
Grassy Branch	0.05	0.041	82.0%	0.042	84.0%	8.1

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	5	0.079
Engineering Plan Review	11	0.494
Sketch Plan Review	17	0.628
Totals	33	1.201

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.108
Engineering Plan Review	4	0.121
Sketch Plan Review	8	0.201
Totals	16	0.430