

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.271	70.3%	6.855	91.4%	3.3
Crooked Creek	1.9	1.125	59.2%	1.694	89.2%	2.5
Olde Sycamore	0.15	0.042	28.0%	0.042	28.0%	2.0
Tallwood	0.05	0.019	38.0%	0.019	38.0%	1.7
Grassy Branch	0.05	0.041	82.0%	0.042	84.0%	2.6

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	2	0.034
Engineering Plan Review	13	0.531
Sketch Plan Review	17	0.633
Totals	32	1.198

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	5	0.106
Engineering Plan Review	4	0.121
Sketch Plan Review	6	0.126
Totals	15	0.353