

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.403	72.0%	6.891	91.9%	1.4
Crooked Creek	1.9	1.133	59.6%	1.709	89.9%	3.2
Olde Sycamore	0.15	0.045	30.0%	0.045	30.0%	3.5
Tallwood	0.05	0.022	44.0%	0.022	44.0%	3.3
Grassy Branch	0.05	0.046	92.0%	0.047	94.0%	3.4

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	2	0.133
Engineering Plan Review	14	0.511
Sketch Plan Review	16	0.736
Totals	32	1.380

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	2	0.051
Engineering Plan Review	7	0.175
Sketch Plan Review	4	0.106
Totals	13	0.332