

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.253	70.0%	6.682	89.1%	0.4
Crooked Creek	1.9	1.129	59.4%	1.686	88.7%	1.0
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	1.3
Tallwood	0.05	0.022	44.0%	0.022	44.0%	1.6
Grassy Branch	0.05	0.043	86.0%	0.044	88.0%	1.7

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.143
Engineering Plan Review	15	0.523
Sketch Plan Review	12	0.557
Totals	30	1.223

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.078
Engineering Plan Review	5	0.197
Sketch Plan Review	6	0.120
Totals	15	0.395