

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.298	70.6%	6.749	90.0%	7.3
Crooked Creek	1.9	1.158	60.9%	1.767	93.0%	10.5
Olde Sycamore	0.15	0.040	26.7%	0.040	26.7%	9.8
Tallwood	0.05	0.022	44.0%	0.022	44.0%	8.2
Grassy Branch	0.05	0.045	90.0%	0.046	92.0%	10.0

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.091
Engineering Plan Review	13	0.625
Sketch Plan Review	14	0.528
Totals	30	1.244

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.078
Engineering Plan Review	4	0.145
Sketch Plan Review	7	0.172
Totals	15	0.395