

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.228	69.7%	6.661	88.8%	3.2
Crooked Creek	1.9	1.207	63.5%	1.678	88.3%	3.4
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	3.2
Tallwood	0.05	0.020	40.0%	0.020	40.0%	2.9
Grassy Branch	0.05	0.039	78.0%	0.040	80.0%	3.4

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.091
Engineering Plan Review	16	0.557
Sketch Plan Review	12	0.386
Totals	32	1.034

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.125
Engineering Plan Review	5	0.173
Sketch Plan Review	8	0.152
Totals	17	0.450