

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.246	69.9%	6.658	88.8%	2.5
Crooked Creek	1.9	1.184	62.3%	1.691	89.0%	1.9
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	2.1
Tallwood	0.05	0.022	44.0%	0.022	44.0%	2.1
Grassy Branch	0.05	0.041	82.0%	0.042	84.0%	1.7

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	2	0.081
Engineering Plan Review	18	0.851
Sketch Plan Review	13	0.278
Totals	33	1.210

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.073
Engineering Plan Review	5	0.197
Sketch Plan Review	6	0.137
Totals	14	0.407