

### Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow <sup>1</sup> (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.203	69.4%	6.668	88.9%	1.3
Crooked Creek	1.9	1.055	55.5%	1.637	86.1%	2.4
Olde Sycamore	0.15	0.046	30.7%	0.046	30.7%	1.6
Tallwood	0.05	0.022	44.0%	0.022	44.0%	1.7
Grassy Branch	0.05	0.045	90.0%	0.046	92.0%	1.1

<sup>1</sup>Based on a 12-month rolling average.

### Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.251
Engineering Plan Review	11	0.312
Sketch Plan Review	15	0.676
<b>Totals</b>	<b>30</b>	<b>1.239</b>

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.064
Engineering Plan Review	7	0.175
Sketch Plan Review	4	0.055
<b>Totals</b>	<b>15</b>	<b>0.294</b>