

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.243	69.9%	6.675	89.0%	2.9
Crooked Creek	1.9	1.137	59.8%	1.644	86.5%	2.5
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	2.6
Tallwood	0.05	0.022	44.0%	0.022	44.0%	2.5
Grassy Branch	0.05	0.042	84.0%	0.043	86.0%	2.9

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.143
Engineering Plan Review	16	0.768
Sketch Plan Review	17	0.468
Totals	36	1.379

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.078
Engineering Plan Review	5	0.197
Sketch Plan Review	7	0.146
Totals	16	0.421