

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.168	68.9%	6.760	90.1%	3.2
Crooked Creek	1.9	1.223	64.4%	1.781	93.7%	3.0
Olde Sycamore	0.15	0.039	26.0%	0.039	26.0%	3.4
Tallwood	0.05	0.017	34.0%	0.017	34.0%	3.2
Grassy Branch	0.05	0.036	72.0%	0.037	74.0%	2.9

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.037
Engineering Plan Review	14	0.427
Sketch Plan Review	11	0.283
Totals	28	0.747

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	3	0.055
Engineering Plan Review	8	0.195
Sketch Plan Review	9	0.156
Totals	20	0.406