

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.291	70.5%	6.742	89.9%	4.4
Crooked Creek	1.9	1.142	60.1%	1.717	90.4%	3.7
Olde Sycamore	0.15	0.041	27.3%	0.041	27.3%	3.6
Tallwood	0.05	0.021	42.0%	0.021	42.0%	4.0
Grassy Branch	0.05	0.042	84.0%	0.043	86.0%	5.7

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	7	0.173
Engineering Plan Review	12	0.519
Sketch Plan Review	16	0.607
Totals	35	1.299

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	5	0.113
Engineering Plan Review	4	0.168
Sketch Plan Review	7	0.149
Totals	16	0.430