

Water Reclamation Facility Flows

WRF	Permitted Capacity (MGD)	Actual Average Daily Flow ¹ (MGD)	Percent of Actual Flow Used	Actual + Permitted Obligated Flows (MGD)	Percent of Permitted Flow Used	Actual Rainfall (in)
Twelve Mile Creek	7.5	5.270	70.3%	6.728	89.7%	4.1
Crooked Creek	1.9	1.127	59.3%	1.736	91.4%	5.1
Olde Sycamore	0.15	0.040	26.7%	0.040	26.7%	3.3
Tallwood	0.05	0.021	42.0%	0.021	42.0%	2.5
Grassy Branch	0.05	0.042	84.0%	0.043	86.0%	4.1

¹Based on a 12-month rolling average.

Development Flows

12-Mile Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.096
Engineering Plan Review	12	0.619
Sketch Plan Review	14	0.436
Totals	30	1.151

Crooked Creek WRF		
Backlog Type	Number of Projects	Requested Flow (MGD)
Approved – Permit Submittal Pending	4	0.078
Engineering Plan Review	3	0.116
Sketch Plan Review	8	0.201
Totals	15	0.395