

Water Reclamation Facility Flows

| WRF | Permitted Capacity (MGD) | Actual Average Daily Flow ¹ (MGD) | Percent of Actual Flow Used | Actual + Permitted Obligated Flows (MGD) | Percent of Permitted Flow Used | Actual Rainfall (in) |
|-------------------|--------------------------|--|-----------------------------|--|--------------------------------|----------------------|
| Twelve Mile Creek | 7.5 | 5.212 | 69.5% | 6.612 | 88.2% | 1.3 |
| Crooked Creek | 1.9 | 1.212 | 63.8% | 1.736 | 91.4% | 0.6 |
| Olde Sycamore | 0.15 | 0.039 | 26.0% | 0.039 | 26.0% | 0.6 |
| Tallwood | 0.05 | 0.019 | 38.0% | 0.019 | 38.0% | 1.1 |
| Grassy Branch | 0.05 | 0.038 | 76.0% | 0.039 | 78.0% | 0.6 |

¹Based on a 12-month rolling average.

Development Flows

| 12-Mile Creek WRF | | |
|-------------------------------------|--------------------|----------------------|
| Backlog Type | Number of Projects | Requested Flow (MGD) |
| Approved – Permit Submittal Pending | 4 | 0.275 |
| Engineering Plan Review | 14 | 0.372 |
| Sketch Plan Review | 11 | 0.363 |
| Totals | 29 | 1.010 |

| Crooked Creek WRF | | |
|-------------------------------------|--------------------|----------------------|
| Backlog Type | Number of Projects | Requested Flow (MGD) |
| Approved – Permit Submittal Pending | 4 | 0.077 |
| Engineering Plan Review | 5 | 0.173 |
| Sketch Plan Review | 8 | 0.152 |
| Totals | 17 | 0.402 |